




CITY OF LODI

PUBLIC WORKS DEPARTMENT

DOMESTIC WATER SERVICE (3", 4", 6" & 8")



NOTES:

1. METER (IF REQUIRED) WILL BE FURNISHED AND INSTALLED BY CITY.
2. BYPASS MAY BE INSTALLED WITH THE SPECIFIC APPROVAL OF THE PUBLIC WORKS DIRECTOR.
3. PLUG ALL OPENINGS IN BOX.
4. BACKFILL SHALL CONFORM TO STD PLAN 501.
5. ALL FITTINGS MUST COMPLY WITH THE LATEST STATE OF CALIFORNIA NO LEAD REQUIREMENTS.

SHEET 1 OF 2

Dr. KT	No. 1	Date 2/05	Revision REVISED SPOOL LENGTH'S	Appr.	Approved By:	STD PLAN
Ch. WS					Charlie Swinley City Engineer / Deputy Public Works Director	406
Date 12/00					Date RCE No. 52842	